



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE-205

SE-85-4-5  
SL-100-983 (2)  
SL-100-SPE

OTTAWA, January 26, 1971.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,  
St. Catharines, Ontario.

Attention: Mr. E. L. Mills, Manager,  
Instrument Transformer Engineering

Subject: Two Only Ferranti-Packard Type "PUL5" 3200-5 amp.  
60hz 15000 volt Outdoor Current Transformers  
Serial Numbers 2-247772 and 2-247773.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes, to the above-named apparatus.

These transformers are identical to those covered by circular T-19 except for the addition of 40 turns to the secondary winding to obtain the ratio 3200-5.

The accuracy rating is 0.3B2.0 and the nameplate is marked 0.3E0.9.

These transformers are for Ontario Hydro for use at the Scarborough Transformer Station, Toronto, Ontario.

*W.J.S. Fraser*

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. W. R. McEown, D.I. of E&G, Toronto  
Ontario Hydro (through Mr. McEown)