

Department of consumer and corporate affairs / Ministère de la consommation et des corporations

DL-206

DL-100-2/ (1.5),
DL-100-SPE

OTTAWA, February 17, 1971.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,
St. Catharines, Ontario.

Subject: One Only Ferranti-Packard Type "MP25" 20/40-5 amp.,
17250/29800Y-115 volt 60 Hz., 3 phase, 4 wire Y
Outdoor Oil Insulated Metering Equipment Serial
Number 2-241891.

Attention: Mr. L. L. Mills, Manager
Instrument Transformer Engineering

Special approval has been granted by the Standards Branch for use in Canada for billing purposes to the above named apparatus.

The voltage transformers in this metering outfit are rated 17250/29800Y-115 volts (ratio 150:1) and the design is similar to that of the type MP25 covered by circular T-13-2 except for the number of primary turns to obtain this ratio. The serial numbers of these two voltage transformers are 2-241286-87 and the accuracy rating is 0.3% $\frac{1}{2}$, 22 and the nameplate is marked 0.3%.

The current transformers in this metering equipment are type "KC25" which are covered by circular T-14.

This metering equipment is for use by the Windsor Utilities Commission.

W. J. S. Fraser

W. J. S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Windsor Utilities Commission (through Mr. Fleming)
Mr. J. Fleming, B.I. of I&G, London.