



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE-207

SL-85-9
SL-100-974 (P)
SL-100-SPE

OTTAWA, February 18, 1971.

SPECIAL APPROVAL

Granted to: I.T.E. Circuit Breaker (Canada) Limited
Eastern Power Devices Division
2401 Dixie Road
Port Credit, Ontario.

Attention: Mr. K. Powell,
Engineering Technologist

Subject: Four Only I.T.E. Circuit Breaker Type "MCL5M1"
15kv, 2400/1600-5 amp., 60hz Current Transformers
Serial Numbers 5769, 5770, 5771 and 5772

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are through type with single tapped secondary windings.

The secondary terminals are marked X1, X2 and X3. The 2400-5 amp. ratio is obtained from X1 and X3 and the 1600-5 amp. ratio is obtained from terminals X1 and X2.

The accuracy rating marked on the nameplates is 0.3B0.2, B0.5, B0.9; 0.6B(2 x 0.9).

These transformers are for use at the Ottawa King Edward Transformer Station by Ontario Hydro.

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. J. J. Drolet, D.I. of E&G, Ottawa
Ontario Hydro (through Mr. Drolet)