

SPE-0209

Department of Consumer and Corporate Affairs / Ministère de la consommation et des corporations

SP-107

SP-05-33  
SP-100-01  
SP-100-02

Ottawa, March 12, 1971.

SPECIAL APPROVAL

Granted to: Trench Electric Limited,  
350 Midwest Road,  
Scarborough, Ontario.

Attention: Mr. R. L. Ent-Veen,  
Sales Department.

Subject: Four Only Balteau Type "VLT-15P" Voltage Transformers  
11400-120-120 volts 60 hz

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to four units of the above-named apparatus. The serial numbers are:

33042/0170  
33042/0270  
33042/0370  
33042/0470

These transformers are a moulded type with two separate identical secondary windings, each producing 120 volts with 11400 volts applied to the primary.

The primary terminals are identified as "H1" and "H2" and the secondary terminals are identified as "Y1-Y2" for one winding and "Y1-Y2" for the other. Terminals "H1", "H2" and "Y1" have the same instantaneous polarity.

The accuracy rating is 0.5% on either secondary with the other unloaded and 0.8% on either secondary with the other loaded with Z burden. The nameplate is marked 0.5L-0.8L.

These transformers are provided with a grounding lug connected electrically to the base, and each secondary terminal is provided with a hole through which, by means of a machine screw, any secondary terminal may be connected to the base and consequently grounded.

To remove the possibility of an unwanted ground at this point, the screw that was supplied with the single transformer was removed at the laboratory and placed in an envelope attached to the transformer. It is understood, of course, that use of this device in service must conform in full with the applicable Electrical Codes and the Standards Branch Instructions regarding the Installation of Electric Meters.

These transformers are for use by Toronto Hydro at 700 Huron Street, Toronto.

This approval cancels Special Approval SPE-200.

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. W. K. McEown, Regional Supervisor of E&G, Toronto  
Toronto Hydro (through Mr. McEown)