

SPE-0211

Ministère de l'énergie et des ressources / Ministère de la consommation et des corporations

SPE-111

SE-15-1-6
SE-100-100(H)
SE-100-SPE

Ottawa, Ontario
April 28, 1971.

SPECIAL APPROVAL

Granted to: Canadian General Electric Company Ltd.,
910 Mansdowne Ave.,
Toronto 4, Ontario.

Attention: Mr. R. D. Maguire,
Manager-Engineering
Distribution & Specialty Transformers

Subject: One Only, Canadian General Electric Type "OV-1"
250,000 CrdY/130,000-115/69-115/69 volts 60Hz
Capacitor Voltage Transformer, Serial Number 707627

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

This capacitor voltage transformer is an assembly of a capacitor and a case containing a type PI-10 intermediate voltage transformer, reactor and protective equipment.

Assembly must be such that the capacitor unit has the same serial number as the base.

The metering accuracy rating is 0.6XYZ and this applies to the full or tapped secondary winding with the tertiary winding unloaded, to the full or tapped tertiary winding with the secondary winding unloaded, and to both windings when the designated burden is divided in any proportion between them.

The metering accuracy rating 1.2Z-1.2Z on either the full winding or the tap applies to the secondary winding when the tertiary winding is loaded with Z burden or vice versa. The accuracy rating marked on the nameplate is 0.3XYZ.

