



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPF-216

SE-85-19

SL-100-381

SL-100-SPF

OTTAWA, June 10, 1971.

SPECIAL APPROVAL

Granted to: Emile Haefely and Co. Ltd.,
Basel, Switzerland.

Attention: Mr. A. Baumgartner,
Chief Sales Engineer.

Subject: Four Only Haefely Type VFOS765, Voltage Transformers,
765,000 GrdY/450,000-120-75 volts, 60Hz, serial numbers
690896, 690897, 690898 and 690899.

Special Approval has been granted by the Standards Branch for use
in Canada for billing purposes to the above-named apparatus.

These transformers are two-section bushing type. Assembly must be
such that the two sections bear the same serial numbers.

The accuracy marking on the nameplate is 0.3WXYZ,ZZ for the 120 volt
(X) winding and 0.6WXYZ for the 75 volt (Y) winding with the proviso that
the total simultaneous burden on the two secondary windings must not exceed
400 volt amperes.

These transformers were built for Emile Haefely and Co. Ltd. for
Hydro Quebec and will be installed at Montagnais, Quebec.

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. Jules R. Audet, Hydro Quebec
Mr. J. J. Humbert-Droz, Montel Inc.
Mr. J. B. Dumas, Regional Supervisor (E&G) Montreal.