



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-217

SE-85-19

SL-100-381

SL-100-SPE

OTTAWA, June 10, 1971.

SPECIAL APPROVAL

Granted to: Emile Haefely and Co. Ltd.,
Basel, Switzerland.

Attention: Mr. A. Baumgartner,
Chief Sales Engineer.

Subject: Four Only Haefely, Type VEOS 765 Voltage Transformers,
765,000 GrdY/450,000-120/75-120/75-120/75 volts, 60Hz,
serial numbers 690811, 690812, 690813 and 690814.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are two-section bushing type. Assembly must be such that the two sections bear the same serial numbers.

The accuracy marking on the name-plate is 0.3WXYZ,ZZ for the secondary winding designated as X and 0.6WXYZ for the other two secondary windings designated Y and Z respectively with the proviso that the total simultaneous burden on the three secondary windings must not exceed 600 volt amperes.

These transformers were built by Emile Haefely and Co. Ltd. for Churchill Falls Corporation and will be installed at Churchill Falls.

W. J. S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. J. J. Humbert-Droz, Montel Inc.
Mr. R. C. Bruce, Regional Manager, Halifax
Churchill Falls (Labrador) Corporation (forwarded through Montel Inc.)