



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-218

SE-85-4-5  
SL-100-983 (AB)  
SL-100-SPE

OTTAWA, Ontario  
June 11, 1971.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,  
St. Catharines, Ontario.

Attention: Mr. E. L. Mills, Manager  
Instrument Transformer Engineering

Subject: Twelve Only Ferranti-Packard Type "K35" 2500-5 amp.,  
34500 Volts 60 Hertz, Outdoor Oil Insulated Current  
Transformers, serial numbers 2-252510, -511, -512, -513,  
-514, -515, -516, -517, -518, -519, -520 and -521.

Special Approval has been granted by the Standards Branch for use  
in Canada for billing purposes to the above-named apparatus.

These transformers are bushing type, oil immersed, with single  
secondary windings.

The accuracy rating of these transformers is 0.3B2.0 with a rating  
factor of 1.25. The nameplates are marked 0.3B0.9.

These transformers are for Hatch and Associates for installation  
at Sidbec, located at Contrecoeur, Quebec.

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. G. Readman, D.I. of E&G, Trois Rivieres  
Hatch and Associates (through Mr. Readman)  
Mr. J. B. Dumas, Regional Supervisor E&G, Montreal