



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-219

SE-85-4-5
SL-100-65A
SL-100-SPE

OTTAWA, June 25, 1971.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,
St. Catharines, Ontario.

Attention: Mr. E. L. Mills, Manager
Instrument Transformer Engineering

Subject: Two Only Packard Type H45, 100-5 amp.
Current Transformers, One Serial No.
28941, the serial number of the other
cannot be read.

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes to the above-named apparatus.

These transformers are outdoor type and the accuracy rating is
stated to be 0.6B0.5. The general design and construction is similar
to the types D45 and F45 covered by NRC.72.

These transformers are used on Installation No. 9 for the
Alfred Hydro Electric System.

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. J. J. Drolet, D.I. of E&G, Ottawa
Alfred Hydro Electric System (through Mr. Drolet)
Mr. W. R. McEown, Regional Supervisor E&G, Toronto