



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-222

SE-85-92
SL-100-913
SL-100-SPE

SPECIAL APPROVAL

Granted to: British Brown Boveri Ltd.,
Glen House, Stag Place,
London S.W. 1, England.

Subject: Six Only Brown Boveri Type NCaTTT.17.5 p4
2000-5 amp., 17.5kv, 60Hz Current Transformers
Serial Numbers 298817, -18, -19, -20, -21, -22.

Re: Javelin Paper Corporation
Ref: O/55139/FAD/cb

Special approval has been granted by the Standards Branch for use in Canada for billing purposes, to the above-named apparatus.

These transformers are bar type each with three untapped secondary windings identified as cores 1, 2 and 3.

The accuracy rating of cores 1 and 2 is 0.3B2.0 and the nameplates are so marked but the secondary from core 3 has a relaying accuracy rating and may not be used for metering purposes.

These transformers are installed in switchgear at the Javelin Paper Corporation pulp and paper mill at Stevenville, Newfoundland.

W. J. S. Fraser

W.J.S. Fraser,
Chief,
Electricity & Gas Division.

c.c. Mr. J. Bileski, D.I. of E&G, St. John's Nfld.
Brown-Boveri (Canada) Ltd.,
4000 Trans Canada Highway,
Pointe Claire, Que.