



Department of Consumer and Corporate Affairs / Ministère de la consommation et des corporations



SPE-223

SE-85-92

SL-100-193

SL-100-SPE

Ottawa, Ontario

KLA OC9

August 6, 1971

SPECIAL APPROVAL

Granted to: Brown Boveri (Canada) Ltd.
4000 Trans Canada Highway
Pointe Claire, P.Q.

Attention: Mr. K. Gabriel

Subject: Six only-Brown Boveri Current Transformer Type
TMBRh 362 Rated Voltage 315 kv, Rated frequency 60 Hz,
Current rating 2000/1500-5 amps, Core Numbers 1,2,3,4
Accuracy rating on Core No. 3 and 4 only:
06E0.5, 0.3B2.0
Serial Nos. B-296883, -4, -5, -6, -7 and -8.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers have four tapped secondary windings identified as X, Y, Z and W with cores 1, 2, 3 and 4. Current ratings of 2000/1500/1000-5 are available but only the 2000-5 and 1500-5 ratings of cores 3 and 4 are approved for revenue purposes.

These transformers are for use by Hydro-Quebec at Beauharnois, P.Q.

W.J.S. Fraser
Chief, Electricity & Gas Division

c.c. District Inspector (E&G) Montreal
Hydro-Quebec (through Mr. J. Dumas)