

SPE-0225

Department of consumer and corporate affairs / Ministère de la consommation et des affaires corporatives

SPE-0225

SL-100-2

SL-100-3

SL-100-SKA

August 13, 1971.
OTTAWA, Ontario
K1A 0G9

SPECIAL APPROVAL

Granted to: The Town of Fort Macleod,
Electric Department

Subject: Two Only Westinghouse Voltage Transformers
2300-115 volts 60Hz serial numbers 219752
and 285573

Attention: Mr. E. D. Henrie, Electrician
The Town of Fort Macleod.

Special Approval has been granted by the Standards Branch
for use in Canada for billing purposes to the above-named apparatus.

These transformers are wound type with a single primary and a
single secondary winding.

With 2300 volts applied to the primary windings, the secondary
voltage from each transformer is 115 volts.

The accuracy rating of both transformers is 0.6%; 1.2%V.

These transformers are for use by the town of Fort Macleod,
Alberta.

w.j.s.f.
W.J.S. Fraser

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. A. S. Park, D.I. of NSC, Calgary, Alta.