



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-228

SE-85-92
SL-100-913
SL-100-SPE

OTTAWA, Ontario

Sept. 20, 1971.

SPECIAL APPROVAL

Granted to: Brown-Boveri (Canada) Ltd.,
4000 Trans-Canada Highway,
Pointe Clair, 730 P.Q.

Attention: Mr. K. Gabriel

Subject: Three Only Brown-Boveri Type "TMRp 770 D10"
2000-5-5-5-5-5 ampe., 735 kv Current Transformers,
60 Hz Serial Numbers 289767, 289771 and 289772.

Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to the above-named apparatus.

These transformers are post type, oil insulated, each having a single primary winding and 5 untapped secondary windings.

The primary windings are connected to bars just below the hood at the top of the transformer and the secondary windings are connected to terminals inside a terminal box at the base of the transformer where they are marked as cores 1, 2, 3, 4 and 5.

Core 5 has a 60Hz accuracy rating of 0.3B2.0 and is the only one of the five that may be used for metering.

These transformers are for use by Churchill Falls (Labrador) Corporation and will be installed at the switchyard of Churchill Falls Power Project.

W.J.S. Fraser,
Chief, Electricity & Gas Division.

c.c. Mr. J. Bileski, St. John's, Nfld.
Churchill Falls (Labrador) Corporation (through Mr. Bileski)