


Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-229

SE-85-19  
SL-100-381  
SL-100-SPE

OTTAWA, September 21, 1971.

SPECIAL APPROVAL

Granted to: Emile Haefely and Co. Ltd.,  
Basel, Switzerland.

Attention: Mr. A. Baumgartner,  
Chief, Sales Engineer.

Subject: Seven Only Haefely Type VEOS765, Voltage Transformers,  
765,000 Grd/450,000-120-75 volts, 60Hz, serial numbers 690899,  
690896, 690897, 690898, 690900, 690901 and 690902

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are two-section bushing type. Assembly must be such that the two sections bear the same serial numbers.

The accuracy marking on the nameplate is 0.3WXYZ,ZZ for the 120 volt (X) winding and 0.6WXYZ for the 75 volt (Y) winding with the proviso that the total simultaneous burden on the two secondary windings must not exceed 400 volt amperes.

These transformers were built for Emile Haefely and Co. Ltd., for Hydro Quebec and will be installed at Montagnais, Quebec.

This Special Approval supersedes SPE 216 dated June 10, 1971.

*W.J.S. Fraser*  
W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. Jules R. Audet, Hydro Quebec  
Mr. J. J. Humbert-Droz, Montel Inc.  
Mr. J. B. Dumas, Regional Supervisor (E&G) Montreal.