



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-231

1145-57/B81
SL-100-913

Ottawa, October 18, 1971.

SPECIAL APPROVAL

Granted to: Brown-Boveri (Canada) Ltd.,
4000 Trans-Canada Highway,
Pointe Claire 730, Quebec.

Subject: Six Only Brown-Boveri Type "GUG24" 8400-120/70-
120/70 volt 60Hz Voltage Transformers, Serial
Nos. 306060-65.

Attention: Mr. K. Gabriel

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes, to the above-named apparatus.

These transformers are moulded type and each transformer has two identical tapped secondary windings producing 120 volts across the full winding and 70 volts at the tap with rated primary voltage applied.

The accuracy rating of all these transformers on both ratios is 0.3WX.

These transformers are installed in switchgear at the Javelin Paper Corporation pulp and paper mill at Stevenville, Newfoundland.

W.J.S. Fraser

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. J. Bileski, D.I. of E&G, St. John's, Nfld.
Javelin Paper Corporation (through Mr. Bileski).