



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-232

1145-57/C3-T13
SL-100-57(J)
SL-100-SPE

OTTAWA, October 21, 1971.

SPECIAL APPROVAL

Granted to: Canadian Westinghouse Company Limited,
P.O. Box 2220,
London, Ontario.

Subject: Three Only Canadian Westinghouse Type "RCT-5"
1000/500-5 amp., 60Hz Current Transformers,
Serial Numbers 734613, -614, -615.

Attention: Mr. T. W. Kolator, P. Eng., Senior Engineer,
Engineering Department,
Distribution Apparatus Division

Special Approval has been granted by the Standards Branch for use in Canada, for billing purposes to the above-named apparatus.

These transformers are window type each having a tapped secondary winding.

The 60Hz accuracy rating is 0.3B0.1, B0.2, B0.5; 0.6B0.9 on the 500-5 amp. ratio and 0.3B0.1, B0.2, B0.5, B0.9, B1.0, B1.8; 0.6B2.0 on the 1000-5 amp. ratio at a R.F. = 1.33, and the nameplates are stamped 0.6B0.9.

These transformers are for use in Hillcrest High School, Thunder Bay, Ontario by Thunder Bay Hydro.

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. H. Carr, Thunder Bay
Thunder Bay Hydro (through Mr. Carr).