



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-233

SE-85-1-6
SL-100-361(R)
SL-100-SPE

OTTAWA, October 21, 1971.

SPECIAL APPROVAL

Granted to: Canadian General Electric Company Ltd.,
940 Lansdowne Avenue,
Toronto 4, Ontario.

Subject: Two Only Canadian General Electric Type "PVW-5"
2400-120 volts, 60Hz, Voltage Transformers, Serial
Numbers 372856 and 372863.

Attention: Mr. R. D. Maguire,
Manager-Engineering & Laboratory,
Distribution & Specialty Transformers

Special Approval has been granted by the Standards Branch for use
in Canada for billing purposes to the above-named apparatus.

These transformers are identical to the type PV-5 transformers of
the same ratio that received approval under T-22-1 except that they are
installed in a metal oil-filled enclosure.

The accuracy rating 0.3WXY;0.6Z, is the same as that given on the
above circular.

These transformers are for use by Saguenay Transmission at St. Raymond
Paper at Desbiens, Lac St. Jean.

W.J.S. Fraser

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. J. O. Bedard, Quebec
Saguenay Transmission (through Mr. Bedard)