



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-235

1145-4

OTTAWA, Ontario  
November 26, 1971.

SPECIAL APPROVAL

Granted to: Edmonton Power,  
6th Floor, Centennial Library,  
Edmonton 15, Alberta.

Attention: Mr. H. A. Baird, P. Eng.

Subject: Modified Sangamo Type CJ3S Watthour Meters  
for Automatic Meter Reading Trial

Special Approval has been granted by the Standards Branch to Edmonton Power to modify the following Sangamo Type CJ3S Watthour Meters for a forthcoming Automatic Meter Reading Trial. The modification involves the fitting of a magnetic reed switch on the register of each meter, the switch to be operated by a magnet mounted on the test dial.

The meters are:

<u>Serial No.</u>	<u>Edmonton Power</u>	<u>Serial No.</u>	<u>Edmonton Power</u>
7009 253	18 2200	7020 409	18 2235
7009 254	18 2201	7020 410	18 2236
7009 255	18 2202	7020 411	18 2237
7019 447	18 2592	7020 412	18 2238
7019 448	18 2593	7020 502	18 2328
7019 452	18 2597	7020 507	18 2333
7019 463	18 2608	7020 518	18 2344
7019 587	18 2732	7020 533	18 2359
7019 589	18 2771	7020 572	18 2398
7019 629	18 2774	7020 583	18 2409
7019 634	18 2779	7020 602	18 2428
7019 636	18 2781	7020 603	18 2429
7019 795	18 2940	7020 633	18 2459
7019 796	18 2941	7020 649	18 2475
7019 797	18 2492	7020 651	18 2477

The meters may be inspected and sealed and used in billing service. It is understood, of course, that in case of a discrepancy between the telemetered reading and a meter's own register the latter shall be taken as the true reading.

*W.J.S. Fraser*

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. J. Taylor, Edmonton  
Mr. W.A. Sayers, Winnipeg.