



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE-245
1145-57/W57
SL-100-146
SL-100-SPE

OTTAWA, March 22, 1972

SPECIAL APPROVAL

Granted to: E. W. Playford Company Limited,
5861 Upper Lachine Road,
Montreal 261, P.Q.

Attention: Mr. D. P. Burgess

Subject: Six Only Walter Type E40-200N1 Voltage Transformers
230,000 Crd, Y/138,000-115-69 volts, ratio 1200-2000:1;
60Hz, Serial Numbers 318796, 318797, 318798, 318799,
318800 and 318801.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are single-section bushing type.

The accuracy rating on the nameplate is 0.3WXYZ for both the 115 volt (1200/1, 'Y') winding and the 69 volt (2000/1, 'X') winding.

These transformers were built on behalf of E.W. Playford Co. Ltd., by Societe Walter for Hydro Quebec and will be installed at the SIDBEC substation in Vercheres County.

W. J. S. Fraser
W. J. S. Fraser,
Chief,
Electricity and Gas Division

c.c. Mr. Jules R. Audet, Hydro Quebec
Mr. J. B. Dumas, Regional Supervisor E&G, Montreal