



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE-247

1145-57/F2-T13

SL-100-983

SL-100-SPE

OTTAWA, April 12, 1972

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,
St. Catharines, Ontario.

Subject: Fifteen Only Ferranti-Packard Type "R"
2000/1000-5 amp., 60 Hz, Window Type
Current Transformers for Oil Immersed
Service, Serial Numbers 2-259950, -51,
-52, -53, -54, -55, -56, -57, -58, -59,
-60, -61, -62, -63 and -64

Attention: Mr. E. L. Mills, Manager,
Instrument Transformer Engineering.

Special Approval has been granted by the Standards
Branch for use in Canada for billing purposes to the above-
named apparatus.

These transformers are window type, the double ratio
being obtained by means of a tap on the secondary winding;
the 2000-5 amp. ratio being available from terminals "X1"
and "X3" and the 1000-5 amp. ratio from terminals "X1" and
"X2".

The accuracy rating on both ratios is 0.3B2.0, RF = 1.0
and the nameplates are marked 0.3B0.9.

These transformers are for use by Calgary Power Limited
and will be installed in 1000kva power transformers to be
used on a 24,940 volt delta system.

W. J. S. Fraser

W. J. S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. A. S. Park, Calgary
Calgary Power (through Mr. Park)