



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-248

1145-57/157  
SI-100-116  
SI-100-870

OTTAWA, May 25, 1972

SPECIAL APPROVAL

Granted to: Hydro Quebec  
201 Jarry St. W.,  
Montreal, Que.

Attention: Mr. Jean Morin, P. Eng.,  
Coordinator, Special Measuring  
Electrometry Service.

Subject: Six Only Walter Type E40-200N1 Voltage Transformers  
230,000 Grd, Y/138,000-115-69 volts, ratio 1200-2000:1;  
60 Hz, Serial Numbers 318796, 318797, 318798, 318799,  
318800 and 318801.

Under Special Approval SPE-245, dated March 22, 1972, use of the above Walter Voltage Transformers was granted for installation at Hydro-Quebec SIDBEC substation in Vercheres County.

This is to advise that the Approval remains in force if the said transformers are installed at the Hydro-Quebec Matapedia substation.

W.J.S. Fraser  
Chief,  
Electricity and Gas Division

cc. Mr. J.E. Dumas, Regional Supervisor,  
E & G, Montreal

Mr. J.O. Bedard, District Inspector,  
Quebec