



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE-249

1145-4  
1145-57/S2

Ottawa, June 15, 1972

SPECIAL APPROVAL

Granted to: Edmonton Power,  
6th Floor, Centennial Library,  
Edmonton, Alberta.

Attention: Mr. H. A. Baird, P. Eng.,  
Control and Protection  
Engineering Director.

Subject: Modified Sangamo Type CJ3S Watthour  
Meters for Automatic Meter Reading Trial

Special Approval has been granted by the Standards Branch to Edmonton Power to modify the following Sangamo Type CJ3S Watthour Meters by fitting Sangamo Remote Reading transmitting registers type ED. This is for the purpose of Automatic Meter Reading Trials.

The meters are:

<u>Serial No.</u>	<u>Edmonton Power No.</u>
7019463	182608
7020572	182398
7019636	182781
7020518	182344

The meters may be inspected and sealed and used in a billing service. It is understood, of course, that in case of a discrepancy between the telemetered reading and a meter's own register the latter shall be taken as the true reading.

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. J. Taylor, Edmonton  
Mr. W.A. Sayers, Winnipeg