



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE-250

1145-57/C4-384

SL-100-384

SL-100-SPE

OTTAWA, July 4, 1972.

SPECIAL APPROVAL

Granted to: ASEA Limited,
One Bentall Centre,
505 Burrard Street,
Vancouver 1, B.C.

Subject: Six Only ASEA Type "IMBA-362A2" 100x200-5-5
Amp., 60 Hz, 36kv Current Transformers, Serial
Numbers 6120233-34-35, 6164916-17-18.

Attention: Mr. S. Thomson,
Assistant District Manager

Special Approval has been granted by the Standards
Branch for use in Canada for billing purposes, to the
above-named apparatus.

These transformers are post type with a 2-section
primary winding that can be connected in series or in parallel
by means of links as shown on a small nameplate attached to
the transformers.

Each transformer has two secondary windings connected
to terminals "X1", "X2" for one winding and "Y1", "Y2" for
the other.

The "X" winding is the only winding approved for metering
purposes and its accuracy rating is 0.6B2.0.

The "Y" winding is intended for relaying and is marked
with a relaying accuracy.

These transformers are for use by Alberta Power Limited
at the Yukon Electric Company.

(for)

W.J.S. Fraser,
Chief,

Electricity and Gas Division

c.c. Mr. R.G.D. Ward
Alberta Power Limited (through Mr. Ward)

Standards Branch
Direction des normes