



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-251

1145-57/C3-900

SL-100-900

OTTAWA, July 5, 1972.

SPECIAL APPROVAL

Granted to: Canadian Westinghouse Company Ltd.,
Distribution Apparatus Plant,
P.O. Box 5220,
London, Ontario.

Subject: Three Only Canadian Westinghouse Type KT-15
50/25-5 amp. 60Hz, 15kv Current Transformers,
Serial Numbers 768231-32-33.

Attention: Mr. T. W. Kolator, P. Eng.,
Senior Engineer,
Engineering Department,
Distribution Apparatus Division.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers have a single primary winding and a single tapped secondary winding. The terminals of the secondary winding are identified as "X1", "X2" and "X3" with the current rating 50-5 ampere available from "X1-X3" and the 25-5 ampere rating is available from "X1-X2".

The accuracy rating of this transformer is 0.3B2.0 on the 50-5 ampere and 0.3B0.2 on the 25-5 ampere current rating.

These transformers will be used by Maritime Electric, 139 Grafton Street and will be installed at the University of P.E.I.

(for) W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. J. F. Strain, Charlottetown
Maritime Electric (through Mr. Strain)