



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-253

SL-100-880
1147-57/M5-880
SL-100-SPE

OTTAWA, July 7, 1972.

SPECIAL APPROVAL

Granted to: Norwood Public Utilities Commission,
Norwood, Ontario.

Subject: Two Only, Moloney "Potential" Type Transformers
575-115 volts, 60 Hz, .050 kva, Serial Nos.
100502 and 100505.

Special Approval has been granted by the Standards Branch,
for use in Canada for billing purposes, to the above-named
apparatus.

These are small single ratio transformers with cores
constructed of stacked laminations.

This approval is restricted to the use of these trans-
formers with a secondary burden consisting of one potential
coil (120 volt) of a Sangamo Type 4L2 Watthour Demand meter.
The Accuracy Class at this burden for No. 100502 is 0.6 and
for No. 100505 is 1.2.

The transformers are for use at Excel Feeds Ltd.

(for)

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. T. Murphy, D.I. of E&G, Belleville