



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE-254

SL-100-517
SL-100-SPE
1145-57/F2-T14

OTTAWA, July 13, 1972

SPECIAL APPROVAL

Granted to: Great Lakes Power Company Ltd.,
Sault Ste. Marie, Ontario.

Attention: Mr. Gordon Stone,
Meter Dept.

Subject: Three Only, Ferranti-Packard Type VU8.7
Voltage Transformers, Voltage Rating
7200-240, Serial Nos. 2-242625, 2-258673,
2-258674.

Special Approval has been granted by the Standards Branch, to the above-named apparatus, for use in Canada for billing purposes.

Except for the secondary voltage, 240, these transformers are similar to the type VU8.7 covered by Approval Notice T-13-2.

This Approval covers the use of these transformers with one burden only, viz. the voltage coil of a Sangamo type KWS, 240 volts, combination meter. The accuracy class with this burden is 0.3.

These transformers are for use by Great Lakes Power Company at three small trailer parks.

(for) W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. G. O. Piirainen, Sudbury, Ontario.