



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

SPE - 259

1145-57/C4-384  
GL 1145-57/C4-384(R)

OTTAWA, November 14, 1972.

SPECIAL APPROVAL

Granted to: ASEA Limited,  
One Bentall Centre,  
505 Burrard Street,  
Vancouver 1, B.C.

Subject: Three Only ASEA Type "IMBA36A2" 400 x 200  
-5 -5 Amp: 60 Hz 34.5 Kv Current Trans-  
formers, Serial Numbers 6198255, -256,  
-257

Attention: Mr. S. Thomson,  
Assistant District Manager

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above named apparatus.

These transformers are post type with 2-section primary windings that can be connected in series or in parallel by means of links as shown on a small plate attached to the transformer.

Each transformer has two secondary windings connected to terminals "S1", "S2" for one winding and "R1", "R2" for the other.

The "S" winding is the only winding approved for metering purposes and its accuracy rating is 0.6B1.0.

The "R" winding is intended for relaying and is marked with a relaying accuracy.

---

These transformers are for use at the Yukon Electric Company, Whitehorse, Yukon.

W.J.S. Fraser,  
Chief,  
Electricity and Gas Division

c.c. Mr. R.G.D. Ward, D.I. of  
E & G Vancouver.  
Yukon Electric Co.  
(through Mr. Ward)