



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-261

1145-57/F2-517
GL 1145-57/F2-517 (AA10)
SL-100-SPE

OTTAWA, November 28, 1972.

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,
St. Catharines, Ont.

Subject: Twelve Only Ferranti-Packard Type "VEA" Auxiliary
Voltage Transformers 105-120 Volts 60Hz
Serial Numbers 2-270315-326

Attention: Mr. E.L. Mills, Manager
Instrument Transformer Engineering

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are moulded design auto-transformers with single tapped windings.

The start of the windings goes to terminals "H1" and "X1"; "H2" is the tap and "X2" is the full winding and the ratio is 8.75:10 giving 120 volts across X1-X2 with 105 volts applied across H1-H2.

The accuracy rating is 0.3WXYZ and the nameplates are marked 0.3Z.

These transformers will be used with certain DS15 Metering Outfits owned by Hydro Quebec to produce 120 volts from the voltage transformers rated at 13860Y/8000-100 volts to get an overall voltage ratio of 70:1. The DS15 Metering Outfits are covered by NRC 72.

W.J.S. Fraser
W.J.S. Fraser,
Chief, Electricity & Gas
Division.

c.c. Mr. J. B. Dumas, Montreal
Hydro Quebec (through Mr. Dumas)