



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SEP-262

GL 1145-1 (SL-100-E)
C 1145-1

OTTAWA, February 17, 1973.

SPECIAL APPROVAL

Granted to: Hydro Quebec
Rimouski Region

Subject: One Only Westinghouse Style H-16411 2300-115 volt
60 Hz Voltage Transformer serial number 111651

Attention: Mr. J.O. Bedard
D.I. of E & G Quebec

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes, to the above-named apparatus.

These transformers have a stacked core with cast iron end caps and have short leads for primary and secondary connections.

The accuracy rating is 0.6 WX; 1.2 Y which is not marked on the nameplate.

This approval covers other units of the same rating and having the same style number owned by Quebec Hydro and being used in the Rimouski Region.

W.J.S. Fraser
Chief,
Electricity and Gas Division

c.c. Quebec Hydro (through Mr. Bedard)