



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-263

G 1145-57/087
GL 1145-57/087

OTTAWA, February 26, 1973.

SPECIAL APPROVAL

Granted to: Ontario Hydro,
620 University Avenue,
Toronto 2, Ontario.

Subject: Ten Only Statrel Type CCR-2 2-wire to
3-wire Conversion Relays Serial Numbers
1 to 10 inclusive.

Attention: Mr. George R. Long,
Meter Engineer,
Power Systems Operations Division.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-mentioned apparatus.

These relays are designed to generate a 3-wire SPDT output from a 2-wire SPST input.

This approval covers the use of these relays at room temperature only.

These relays will be used by Ontario Hydro to produce a 3-wire output from the 2-wire output of Trivectors.

W.J.S. Fraser,
Chief,
Electricity and Gas Division.

c.c. Mr. F. W. Mason, D.I. of E&G, Toronto