



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-267

G 1145-57/C4-384
GL 1145-57/C4-384(T)

OTTAWA, March 30, 1973.

SPECIAL APPROVAL

Granted to: ASEA Limited,
One Bentall Centre,
505 Burrard Street,
Vancouver 1, B.C.

Subject: Two Only ASEA Type "IMBA 60 A2"
1200 x 800 x 600 x 400 x 300 x
200 - 5 - 5 Ampere 60 Hz 69 Kv
Current Transformers Serial
Numbers 5854-690 and 5854-698

Attention: Mr. S. Thomson
Assistant District Manager

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are post type with a 2-section primary windings that can be connected in series or parallel; and 2 tapped secondary windings, the latter identified as "X" and "Y".

Only the "X" winding is approved for revenue metering as follows:

Pri	Terminals	Ratio	Approved Accuracy Rating
series	X1 - X4	1200 - 5	0.6B2.0
series	X2 - X4	800 - 5	0.3B2.0; 0.6B1.8
series	X1 - X3	600 - 5	0.3B2.0; 0.6B1.8
par	X2 - X4	400 - 5	0.3B2.0; 0.6B1.8
par	X1 - X3	300 - 5	0.3B2.0; 0.6B1.8
par	X1 - X2	200 - 5	0.6B1.0 no other burden may be used

These two transformers are from a group of 18 similar units delivered in 1966 to West Kootenay Power and Light Company Ltd., Trail, B.C. The remaining 16 transformers of this group are not approved for billing purposes.

W.J.S. Fraser
W.J.S. Fraser
Chief,
Electricity and Gas Division.

c.c. Mr. R.G.D. Ward, D.I. of E&G, Vancouver
West Kootenay Power & Light Co. (through Mr. Ward)