



SPE-268

Department of consumer and corporate affairs / Ministère de la consommation et des corporations



G 1144-57/F
GL 1144-57/F
SL-100-E

Ottawa, Ontario
K1A 0C9

April 5, 1973.

SPECIAL APPROVAL

Granted to: Federal Pioneer Ltd.,
1541 Barrington St.,
Halifax, N.S.

Attention: Mr. Jack Levins

Subject: Three Only Federal Pioneer Window
Type 2500-5 Amp., 60 Hz Current
Transformers, no serial numbers

Special approval has been granted by the Standards Branch for use in Canada for billing purposes to the above-named apparatus.

These transformers are window-type and from the information on hand, they have a single secondary winding and an accuracy rating of 0.3B2.0 but do not have a type designation or serial numbers.

These transformers are in service at the Antigonish High School in Antigonish, Nova Scotia.

W.J.S. Fraser

W.J.S. Fraser
Chief,
Electricity and Gas Division.

cc. Mr. R.C. Bruce, D.I. of E&G, Halifax, N.S.
Town of Antigonish (through Mr. Bruce)