



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



SPE-273

GL 1145-57/J213-893

G 1145-57/J213-893

OTTAWA, July 11, 1973

SPECIAL APPROVAL

Granted to: I.T.E. Circuit Breaker (Canada) Limited
Eastern Power Devices Division,
2401 Dixie Road,
Port Credit, Ontario.

Attention: Mr. D. W. Gardiner, Chief Engineer,
Transformer, Rectifier & Capacitor
Section.

Subject: Three only, I.T.E. Circuit Breaker Bushing
Type Current Transformers, Serial Numbers
7073, 7074 and 7077.

Special Approval has been granted for use of the subject transformers for billing purposes by B.C. Hydro and Power Authority, at the Peace River Hydro Electric Project, Chetwynd, B.C.

These transformers are of the "through" or "bushing" type with a single secondary winding and a current ratio of 14000-5 amps.

Their inside and outside diameters are approximately 22½ inches and 27½ inches respectively.

Their accuracy rating is 0.3B2.0 as marked on the nameplates.

(W.J.S. Fraser)
W.J.S. Fraser,
Chief,
Electricity and Gas Division.

C.c. Mr. R.G.D. Ward, Vancouver
B.C. Hydro Power & Authority (through Mr. Ward)