



Department of consumer and corporate affairs / Ministère de la consommation et des corporations

J

114-0274

G 1144-57/C2
GL 1144-57/C2

Ottawa, Ontario
K1A 0C9

August 31, 1973

SPECIAL APPROVAL

Granted to: Canadian General Electric Co. Ltd.,
Power Transmission and Distribution Dept.,
Power Transformer Section,
201 Woodlawn Road West,
Guelph, Ontario.

Subject: Six only Canadian General Electric
Bushing Type 1000/500-5 Amperes,
60 Hz Current Transformers,
Serial Numbers 19382, 19383, 19384, 19385,
19386, and 19387.

Attention: Mr. A. Thomas
Medium Power Engineering.

Special Approval has been granted by the Standards Branch for use of the subject transformers for revenue metering.

These transformers are bushing type with single tapped secondary windings identified as X1, X2 and X3. Terminals X1 and X3 are used for the 1000-5 ampere ratio and X1 and X2 for the 500-5 ampere ratio.

The accuracy ratings are 0.3 B 2.0 for the higher ratio and 0.3 B 0.5; 0.6 B 1.0 for the lower.

These transformers are to be mounted on (2) 30/40/50/56 MVA Power Transformers, Serial Numbers 288215-6 on C.G.E. No. 9261 -77- 5640, for use by Calgary Power Limited.

W.J.S. Fraser
W.J.S. Fraser
Chief,
Electricity and Gas Division

c.c.Mr. A. Park
J.M. Taylor