



SPE-275

OTTAWA, Ontario

K1A 0C9

January 24, 1974

Your file    Votre référence

Our file    Notre référence

GL 1145-57/C291-164

G 1145-57/C291-164

SPECIAL APPROVAL

Granted to:    G.E.C. Switchgear Ltd.,  
Higher Openshaw,  
Manchester,  
U.K.

Subject:        6 only current transformers,  
Style No. CT ES5654, 4000/3000/2000-5 amp.  
60 Hz, Serial Nos. 56418H1R3-Y3-B3 and  
56418K1R3-Y3-B3

Attention:      Mr. R. K. Cragg,  
Contracts Dept.

Special Approval has been granted by the Standards Branch for use in Canada for billing purposes to the above named apparatus.

These transformers are bushing type with tapped secondary.

Identification of the secondary terminals is provided on AEI drawings E6327448-9.

Any of the three available ratios may be used.

Accuracy rating is 0.3B2.0.

These transformers are installed in switchgear at the Come-by Chance refinery at Come-by-Chance, Nfld., to measure the power and energy supplied by Newfoundland and Labrador Power Commission.



(for) W.J.S. Fraser,  
Chief,  
Electricity and Gas Division.

c.c. Mr. J. Strachan  
Nfld. & Labrador Power Commission (through Mr. Strachan)  
Procon (through Mr. Strachan)