



OTTAWA, Ontario
K1A 0C9

February 26, 1974

Your file *Voire référence*

Our file *Notre référence*

G 1145-57/C301
GL 1145-57/C301

SPECIAL APPROVAL


Granted to: Hydro-Quebec, Region Richelieu
 1450, rue City Councillors
 Montreal 111, Que.

Attention: M.R. Methot
 Chef de section
 Mesurage

Subject: Two only, Current Transformers
 Canadian Westinghouse type OCT 46
 50/100 - 5A, 60 Hz
 Acc. class 0.3B2.0

Special Approval has been granted by the Standards Branch to the above named apparatus for use in Canada for billing purposes.

These transformers are used to measure the electricity supplied to Goodyear Tire & Rubber at 46 Kv, by Hydro-Quebec at St. Hyacinthe, Installation number 19860-9998-0-02.


W.J.S. Fraser
Chief,
Electricity and Gas Division.