SPE-278

OTTAWA, Ontario KlA OC9

April 10, 1974

Your file Votre reférence

Our Notre reference

G 1145-57/C291-164 GL 1145-57/C291-164

## SPECIAL APPROVAL

Granted to:

G.E.C. Switchgear Ltd.,

Higher Openshaw

Manchester

U.K.

Attention:

Mr. R.K. Cragg

Contracts Department

Subject:

Two voltage transformers

AEI Type PTA 893

Primary voltage 13.8 Kv, 3-ph.

Secondary voltages 115-197

60 Hz

Serial Nos. 56418.H, 56418.K

Special Approval has been granted by the Standards Branch to the above named apparatus for use in Canada for billing purposes.

These transformers are 3-phase, oil filled, with drawable, cubicle type.

Secondaries are tapped and the full or tapped connections may be used. Terminal identification is provided on AEI drawing No. D5326243.

Accuracy rating is 0.3WXY, 0.6Z

These transformers are installed in switchgear at the Come-by-Chance refinery at Come-by-Chance, Nfld., to measure the power and energy supplied by the Newfoundland and Labrador Power Commission.

w.J. S. Fraser

W.J.S. Fraser

Chief,

Electricity and Gas Division

c.c. Mr. J. Strachan Nfld. & Labrador Power Comm. (through Mr. Strachan) Procon (through Mr. Strachan)