



OTTAWA, May 6, 1974

Your file votre référence

Our file Notre référence

GL 1145-57/B8-913
G 1145-57 -913

SPECIAL APPROVAL

Granted to: Brown Boveri (Canada) Ltd.,
 4000 Trans Canada Highway,
 Pointe Claire, Que.

Attention: Mr. J. F. Allaire

Subject: Three Brown-Boveri Current Transformers
 Type TMBRh 362
 Rated voltage 345 kv
 Primary current 1200/800/600 A
 Secondary current 5A
 Accuracy rating at 60 Hz 0.3B1 on 1200:5A ratio
 Serial Nos. HU-327-064, 065 and 066

Special Approval has been granted by the Standards Branch, for use in Canada for billing purposes, to the above-named apparatus.

These are oil immersed, hermitically sealed current transformers having two tapped secondary windings.

Only the 1200:5A ratio, using terminals X1-X4, Y1-Y4, is approved for billing purposes.

These transformers are for use by the New Brunswick Electric Power Commission at their Keswick Station.

W.J.S. Fraser,
Chief, Electricity and Gas Division.

c.c. Mr. J. F. Villeneuve, D.I., (E&G) Fredericton
New Brunswick Electric Power Commission (through Mr. Villeneuve)