



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

SPE-279-Rev 1

OTTAWA, August 17, 1977

Your file Votre référence

Our file Notre référence

G6565-B8-32

SPECIAL APPROVAL

Granted to: New Brunswick Electric Power Commission
King Street, Fredericton, N.B.

Attention: Mr. P. Fitzpatrick, P.Eng.

Subject: Three Brown-Boveri Current Transformers
Type TMRh 362
Rated voltage 345 kV
Primary currents: 1200/800/600 A
Secondary current: 5 A
Accuracy rating at 60 Hz:
 1200-5A 0.3Bl.0
 800-5A 0.6Bl.0
Serial Nos. HU-327-064, 065 and 066

This is an addition to the Special Approval SPE-279, May 6, 1974, which remains in effect. It includes the use of the 800-5A current rating for revenue metering in Canada with an accuracy rating of 0.6Bl.0 using terminals $X_1 - X_3$, $Y_1 - Y_3$.

These transformers are for use by the New Brunswick Electric Power Commission at their Keswick Station.

D.L. Smith
Chief, Electricity and Gas Division

c.c. Mr. J.F. Villeneuve, D.I., (E&G) Fredericton