Corporate Affairs corporations

OTTAWA, July 9, 1974

Your lim Votre rélérence

Our lie Notre référence GL 1145-57/L1-153

G 1145-57/L1-153

## SPECIAL APPROVAL

Granted to:

Landis & Gyr, Ltd., 2063 Chartier Street,

Dorval, Que.

Attention:

Mr. B. W. Krutina

President.

Subject:

Two, Landis & Gyr Loss Meters

Type 30 Fihr6 5A, 60Hz, 3-phase

Ser. #38984-318

0.85848 ohms/phase Kh = .025 Wh/rev. Ki = 1.0 Wh/impulse

Ser. #38984-319

0.57288 ohms/phase
Kh = .0166 Wh/rev.
Ki = 1.0 Wh/impulse

Special Approval is granted by the Standards Directorate for use of the subject equipment for billing purposes in Canada.

These meters are arranged to read out in secondary watthours. To obtain the primary losses, the reading must be multiplied by the square of the CT ratio. They must be used only with a transmission line having the specified resistance.

These meters are for use at the French Village station of the Nova Scotia Power Corporation.

It can be assumed that they have a six year seal period. Instructions for reverification will be furnished by the Standards Laboratory.

D. L. Smith, Chief, Electricity & Gas Division.

c.c. District Inspector Halifax
NSPC c/o Mr. N.B. Hutt (through Mr. Bruce)