



OTTAWA, November 15, 1974

Your file Votre référence

Our file Notre référence

GL 1145-57/C2-539

SPECIAL APPROVAL

Granted to: Canadian General Electric Company Ltd.,
Power Delivery Dept.,
940 Lansdowne Ave.,
Toronto, Ontario.
M6H 3Z4

Attention: Mr. R. D. Maguire,
Manager-Engineering
Distribution & Specialty Transformer Section

Subject: Six C.G.E. Type VCM230 Voltage Transformers
230,000 Grd.Y/138000-115/69-115/69 volts,
60Hz, Ser. Nos. 920573-4-5-6-7-8.

Special Approval has been granted by the Standards Directorate for use in Canada for billing purposes to the above-named apparatus.

These transformers are oil filled, cascade type intended for outdoor service connected line-ground. They are similar to those covered by S-EA-587 but the accuracy of the subject transformers is 0.3ZZ.

These transformers are for use by Manitoba Hydro at their Ridgeway and St. Vital stations.

D. L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. J. Bileski
Manitoba Hydro (through Mr. Bileskie)

B. Sullivan