



OTTAWA, November 25, 1974

Your file    Votre référence

Our file    Notre référence

GL 1145-57/M5-880

SPECIAL APPROVAL

Granted to: Bowmanville Public Utilities Commission,  
19 King Street West,  
Bowmanville, Ontario.

Attention: Mr. M. J. Watson,  
Manager.

Subject: Two, Moloney Electric Company  
Instrument Transformer Metering Units  
3 Phase, 4-wire, 60 Hz, 2300:115 volts  
Ser. # 162481: 50/100-5A  
Ser. # 138690: 25/50-5A

Special Approval is hereby granted for use of the  
subject equipment for billing purposes in Canada.

These oil filled metering units contain three  
current transformers and two voltage transformers. The  
former are dual ratio by means of series-parallel con-  
nections links located within the tank.

There is no type designation and the accuracy is  
not marked on the nameplate. The measured accuracy of  
unit #162481 is as follows:

CT: 0.3B0.9, 0.6B2.0  
VT: 0.3WXY, 1.2Z

These units are for use at the following locations:  
#162481: Bayridge Training School  
#138690: Memorial Hospital.

D. L. Smith,  
Chief,  
Electricity and Gas Division.

c.c. District Inspector E&G, Toronto