



OTTAWA, January 14, 1975

Your file Votre référence

Our file Notre référence

G 1144-57/C3
GL 1145-57/C3-57

SPECIAL APPROVAL

Granted to: Canadian Westinghouse Ltd.,
Distribution Apparatus Division,
P.O. Box 5220,
London, Ontario
N6A 4N6

Attention: Mr. T. W. Kolator, P. Eng.,
Senior Engineer,
Protective Products,
Distribution Apparatus Division.

Subject: Three Only Canadian Westinghouse Type RCT-5
1600/5A Current Transformers, Serial Nos.
947428, 947429 and 947430.

Special Approval has been granted by the Standards Directorate for use in Canada for billing purposes to the above named apparatus.

These transformers are ring type with an accuracy of 0.3B2.0.

The three units will be installed at St. Francis Xavier University, Antigonish, N.S.

D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. R.C. Bruce, Halifax
N.S.P.C. - through Mr. Bruce