

OTTAWA, April 7, 1975

Your file Votre référence

Our file Notre référence

GL 1145-57/C2-539

SPECIAL APPROVAL

Granted to: Canadian General Electric Company Ltd.,
Power Delivery Dept.,
940 Lansdowne Ave.,
Toronto, Ontario.
M6H 3Z4


Attention: Mr. R.D. Maguire,
Manager-Engineering
Distribution & Specialty Transformer Section.

Subject: Eleven C.G.E. Type VCM 230 Voltage
Transformers 230,000 Grd. Y/138,000-115/69-
115/69 volts, 60 Hz, Serial Nos. 924677 to
924681 and 927901 to 927906 inclusive.

Special Approval has been granted by the Standards Directorate for use in Canada for billing purposes on the above-named apparatus.

These transformers are oil filled, cascade type intended for outdoor service connected line-ground. They are identical to those covered by SPE-283 (Nov. 15, 1974); the accuracy rating is 0.3ZZ.

These transformers are for use by Manitoba Hydro-five transformers to be installed at Jenpeg station and six at Dorsey station.



D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. J. Bileski
Manitoba Hydro (through Mr. Bileski)