



OTTAWA, May 22, 1975

Your file Votre référence

Our file Notre référence

1145-57/C2-767

SPECIAL APPROVAL

Granted to: Canadian General Electric,
 940 Lansdowne Avenue,
 Toronto, Ontario.
 M6H 3Z4

Attention: Mr. R.D. Maguire,
 Manager-Engineering
 Distribution & Specialty Transformers.

Subject: Three General Electric Type JKW-150
 200/400-5 amperes, 60 Hz, Current
 Transformers, Insulation Class 75 Kv,
 Serial Nos. 1005765, 1005766 and 1005767.

Special Approval is hereby granted for use of the subject equipment for billing purposes in Canada.

These butyl-moulded transformers have tapped secondaries of which terminals X_1 , X_2 are used for the high ratio and X_2 , X_3 for the low ratio.

Terminals X_1 and X_2 are the "marked" terminals for the high ratio and the low 2 ratio respectively.

The accuracy rating for both ratios is 0.3B2.0.

These units are for use by Hydro Quebec at Trois Rivieres, Quebec.

D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. District Inspector, E&G, Trois Rivieres, Que.
Hydro Quebec, Trois Rivieres, Que.