



OTTAWA, May 29, 1975

Your file    Votre référence

Our file    Notre référence

GL-1145-57/J213-393

SPECIAL APPROVAL

Granted to:    I.T.E. Circuit Breaker (Canada) Ltd.,  
2401 Dixie Road,  
Mississauga, Ontario.

Attention:    Mr. D. W. Gardner,  
Chief Engineer,  
Transformer, Rectifier & Capacitor Section.

Subject:    Three I.T.E. Circuit Breaker Bushing  
Type Current Transformers, Serial  
Nos. 10916, 10917 and 10918.

Special Approval has been granted for use of the subject transformers for billing purposes by New Brunswick Electric Power Commission. They will be installed in the generation station at Coleson Cove, New Brunswick.

These transformers are of the "through" or "bushing" type with a single secondary winding and a current ratio of 15000-5 amperes.

The inside and outside diameters are approximately 29½" and 34" respectively.

The accuracy rating is 0.3B2.0 as marked on the name plates.

D. L. Smith  
Chief,  
Electricity and Gas Division

c.c. District Inspector, E&G, Fredericton, N.B.