



OTTAWA, July 7, 1975

Your file Votre référence

Our file Notre référence

1145-57/C3-882

SPECIAL APPROVAL

Granted to: Westinghouse Canada Ltd.,
 Box 510,
 Hamilton, Ontario.

Attention: Mr. V. E. Campbell,
 Product Manager,
 Meters & Instruments.

Subject: 50 - Canadian Westinghouse Type D4B-2F
 Polyphase Watthour Meters, 2-element,
 0.12-10A, 120 V, 25 Hz.

Special Approval has been granted by the Standards Directorate for use of the subject meters for billing purposes in Canada.

These transformer type meters are in the flexitest case for switchboard mounting.

They are for use by Ontario Hydro in their Niagara Region.

D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. R.C. Copland, Ontario Hydro,
 Mr. R. R. Urquhart, Ontario Hydro,
 District Inspector (E&G) Hamilton,
 District Inspector (E&G) Toronto.