



OTTAWA, October 3, 1975

Your file Votre référence

Our file Notre référence

GL 1145-57/C3-57

SPECIAL APPROVAL

Granted to: Westinghouse Canada Ltd.,
Distribution Apparatus Division,
P.O. Box 5220,
London, Ontario


Attention: Mr. T.W. Kolator, P. Eng.,
Senior Engineer,
Protective Products,
Distribution Apparatus Division

Subject: Four only Westinghouse Canada Type RCT-5
Current Transformers, Style 593C552G01, ratio
3000/5A, Serial No.'s IA192, IA193, 965116
and 965117, imported from Westinghouse
Electric Company.

Special Approval has been granted by the Standards
Directorate for use in Canada for billing purposes to the
above-named apparatus.

These transformers are ring type with an accuracy of
0.3B2.0.

The four units will be used by Ontario Hydro at St.
Mary's Cement Plant, St. Mary's Ontario.


D.L. Smith,
Chief,
Electricity & Gas Division.

cc: Mr. J. Fleming, D.I., London
Ontario Hydro - through Mr. Fleming