



Consumer and  
Corporate Affairs  
Standards

Consommation et  
corporations  
Normes

SPE-296

OTTAWA, January 26, 1976

*Your file*      *Votre référence*

*Our file*      *Notre référence*

1145-57/C3-57

SPECIAL APPROVAL

Granted to:      Westinghouse Canada Limited,  
                         Distribution Apparatus Division,  
                         P.O. Box 5220,  
                         London, Ontario.

Attention:      Mr. T. W. Kolator, P. Eng.,  
                         Senior Engineer,  
                         Protective Products,  
                         Distribution Apparatus Division.

Subject:      Six only Westinghouse Canada Type RCT-15  
                         Current Transformers, Style 6E0236, ratio  
                         400/200-5A, Serial Numbers from 960162 to  
                         960167 inclusive.

Special Approval has been granted by the Standards Directorate for use in Canada for billing purposes to the above-named apparatus.

These transformers have a metering accuracy of 0.3B0.5 and 0.6B0.9 at 400A, and 0.6B0.2 at 200A tap.

They were purchased by Hamilton Hydro and will be installed at City of Hamilton Power Plant, Control Utilities Power Plant, 51 King Street West, Hamilton, Ontario.

D.L. Smith,  
Chief,  
Electricity and Gas Division.

c.c. Mr. R. N. Beattie, D.I., Hamilton  
Hamilton Hydro, through Mr. Beattie.