中国

Consumer and Corporate Affairs

Consommation et corporations

Consumer Standards Directorate Direction générale des normes SPE-297

Ottawa, Ontario. February 17, 1975.

Your file Votre référence

Our file Notre rétérence

GL-57/F2-387

SPECIAL APPROVAL

Granted to:

Ferranti-Packard Limited, St. Catherines, Ontario.

Attention:

Mr. R. D. MacKimmie,

Manager, Meter Engineering.

Subject:

Three only, Ferranti-Packard, Type KMD46 Metering Outfits, each with three Current Transformers 1500/3000-5 Amp., and three Voltage Transformers 27600/46000 Grd.Y-115 Volts; Serial Numbers 2-417377, 78, 79.

Special Approval has been granted by the Standards Directorate for use in Canada for billing purposes of the above-named apparatus.

Each metering outfit contains 3 type "MC46" voltage transformers as covered by Approval Notice T-13-2 and 3 type "R3" Special current transformers.

Each voltage transformer is single ratio and has an accuracy rating of 0.3WXYZ.

Each current transformer is double ratio by means of a tapped secondary winding with an accuracy rating of 0.3 B-0.1, B-0.5, B-0.9, on both ratios.

The nameplate is marked 0.3Z for the voltage transformers and 0.3 B-0.9 for the current transformers.

The metering outfits are for installation at Valleyfield, Quebec, by Hydro Quebec.

D. L. Smith,

DI Smith.

Chief,

Electricity and Gas Division.

c.c. Mr. P. A. Lebeau, D.I. of E&G, Montreal
Hydro Quebec (through Mr. Lebeau)